

第2 - 4表 配電設備における1需要家当たり停電実績[時間]

会社別 事故・作業別		年 度		H 4		5		6		7		
		事 故	作 業	計	事 故	作 業	計	事 故	作 業	計	事 故	作 業
北 海 道	事 故	10			13			9			8	
	作 業	1									1	
	計	11			13			9			9	
東 北	事 故	8			7			7			6	
	作 業	11			10			5			3	
	計	19			17			12			9	
東 京	事 故	2			2			2			4	
	作 業	2			1			2			2	
	計	4			3			4			6	
中 部	事 故	3			2			18			3	
	作 業	26			16			11			12	
	計	29			18			29			15	
北 陸	事 故	7			7			5			8	
	作 業	14			11			8			13	
	計	21			18			13			21	
関 西	事 故	3			3	(147)		151			3	
	作 業											
	計	3			3	(147)		151			3	
中 国	事 故	8			11			4			6	
	作 業	26			25			6			6	
	計	35			36			11			12	
四 国	事 故	9			30			3			2	
	作 業	11			10			9			10	
	計	20			40			12			12	
九 州	事 故	43			231			4			5	
	作 業	0			0			0			0	
	計	43			231			4			5	
沖 縄	事 故	(87)	107		(81)	93		(34)	47		(12)	29
	作 業		44			24			16			13
	計	(87)	151		(81)	117		(34)	63		(12)	42
全 国	事 故	(1)	8		(1)	28		(25)	31		()	5
	作 業		8			5			3			3
	計	(1)	17		(1)	34		(25)	35		()	8

(備考) 1. ()内の数値は災害によるものの再掲

2. は有効数字に満たない数値

(單位：分)

8	9	10	11	12	13
5	6	8	() 7	6	5
1	1	1		1	1
6	7	9	() 8	7	6
5	6	10	() 6	8	15
3	5	9		10	14
8	11	19	() 16	18	29
4	3	3		2	2
2	2	2		2	2
6	5	5		4	4
2	3	72	(1) 4	11	5
13	12	13		11	15
15	15	85	(1) 15	21	20
9	6	6	() 4	4	4
13	18	20		18	15
22	23	26	() 22	21	18
3	3	31	() 3	3	3
	1	1		1	1
3	3	32	() 3	4	4
5	5	4	(37) 41	4	4
7	7	8		8	8
12	12	12	(37) 50	12	12
6	4	6	(4) 8	5	8
10	10	12		11	12
16	14	18	(4) 19	17	19
55	21	2	(159) 160	15	2
0	0	0		0	
55	21	2	(159) 160	15	2
186	459	47	(292) 311	75	83
17	14	21		28	26
203	473	68	(292) 342	103	109
11	10	17	(21) 25	7	5
4	4	5		5	5
15	14	22	(21) 30	12	10