

第2 - 6表 電源・配電設備総合における1需要家当たり停電実績[時間]

会社別 事故・作業別		年 度		H 4		5		6		7	
北 海 道	事 故		13		15		11		9		
	作 業		11		7		5		5		
	計		24		22		16		14		
東 北	事 故		10		9		8		13		
	作 業		12		12		6		4		
	計		22		21		14		17		
東 京	事 故		3		3		5		5		
	作 業		2		1		2		2		
	計		5		4		7		7		
中 部	事 故		4		5		19		4		
	作 業		26		16		11		12		
	計		30		21		30		16		
北 陸	事 故		8		10		6		9		
	作 業		14		12		8		13		
	計		22		22		14		22		
関 西	事 故		3		4	(178)	183		4		
	作 業										
	計		4		4	(178)	183		4		
中 国	事 故		9		12		5		6		
	作 業		26		25		7		6		
	計		35		37		12		12		
四 国	事 故		9		31		3		2		
	作 業		11		10		9		10		
	計		20		41		12		12		
九 州	事 故		45		262		6		5		
	作 業		0		0		0		0		
	計		45		262		6		5		
沖 縄	事 故	(87)	110	(81)	105	(45)	67	(14)	40		
	作 業		47		31		21		18		
	計	(87)	157	(81)	136	(45)	88	(14)	58		
全 国	事 故	(1)	10	(1)	33	(30)	38	()	6		
	作 業		8		6		4		4		
	計	(1)	18	(1)	39	(30)	42	()	10		

(備考) 1. ()内の数値は災害によるものの再掲

2. は有効数字に満たない数値

(單位：分)

8	9	10	11	12	13
6	7	21	() 10	7	6
3	2	2		2	2
9	9	23	() 12	9	8
6	7	13	() 6	10	17
3	5	9		10	14
9	12	22	() 16	20	31
5	4	4		4	3
2	2	2		2	2
7	6	6		6	5
2	3	74	(2) 5	22	5
13	12	13		11	15
15	15	87	(2) 16	32	20
10	6	8	() 4	5	4
13	18	20		18	14
23	24	28	() 22	22	18
4	4	37	() 4	4	4
	1	1		1	1
4	4	38	() 5	5	5
5	5	5	(38) 43	5	5
7	8	8		9	9
12	13	14	(38) 52	13	13
6	6	6	(4) 8	5	8
10	10	12		11	12
16	16	18	(4) 19	17	19
57	22	2	(211) 214	16	2
0	0	0		0	
57	22	2	(211) 214	16	2
194	462	50	(313) 336	79	96
25	21	29		29	28
219	483	79	(313) 370	108	124
12	11	20	(27) 32	9	6
4	4	5		6	5
16	15	25	(27) 37	14	11