

第2 - 6表 電源・配電設備総合における1需要家当たり停電実績[時間]

会社別 事故・作業別		年 度		6	7	8		
		H 5						
北 海 道	事 故	15		11	9	6		
	作 業	7		5	5	3		
	計	22		16	14	9		
東 北	事 故	9		8	13	6		
	作 業	12		6	4	3		
	計	21		14	17	9		
東 京	事 故	3		5	5	5		
	作 業	1		2	2	2		
	計	4		7	7	7		
中 部	事 故	5		19	4	2		
	作 業	16		11	12	13		
	計	21		30	16	15		
北 陸	事 故	10		6	9	10		
	作 業	12		8	13	13		
	計	22		14	22	23		
関 西	事 故	4	(178)	183	4	4		
	作 業							
	計	4	(178)	183	4	4		
中 国	事 故	12		5	6	5		
	作 業	25		7	6	7		
	計	37		12	12	12		
四 国	事 故	31		3	2	6		
	作 業	10		9	10	10		
	計	41		12	12	16		
九 州	事 故	262		6	5	57		
	作 業	0		0	0	0		
	計	262		6	5	57		
沖 縄	事 故	(81)	105	(45)	67	(14)	40	194
	作 業		31		21		18	25
	計	(81)	136	(45)	88	(14)	58	219
全 国	事 故	(1)	33	(30)	38	( )	6	12
	作 業		6		4		4	4
	計	(1)	39	(30)	42	( )	10	16

(備考) 1. ( )内の数値は災害によるものの再掲

2. は有効数字に満たない数値

(單位：分)

9	10	11	12	13	14
7	21	( ) 10	7	6	10
2	2		2	2	1
9	23	( ) 12	9	8	12
7	13	( ) 6	10	17	16
5	9		10	14	15
12	22	( ) 16	20	31	31
4	4		4	3	12
2	2		2	3	2
6	6		6	6	14
3	74	(2) 5	22	5	3
12	13		10	15	13
15	87	(2) 16	32	20	16
6	8	( ) 4	5	4	6
18	20		17	14	14
24	28	( ) 22	22	18	20
4	37	( ) 4	4	4	2
1	1		1	1	2
4	38	( ) 5	5	5	4
5	5	(38) 43	5	5	5
8	8		8	9	8
13	14	(38) 52	13	13	13
6	6	(4) 8	5	8	4
10	12		12	12	11
16	18	(4) 19	17	19	15
22	2	(211) 214	16	2	13
0	0		0		0
22	2	(211) 214	16	2	13
462	50	(313) 336	79	96	465
21	29		29	28	25
483	79	(313) 370	108	124	490
11	20	(27) 32	9	6	13
4	5		5	5	5
15	25	(27) 37	14	11	19